

Fire Safety & Property Maintenance Inspection Program Public Assembly & Commercial Common Area Check List

SUMMARY REQUIREMENTS (per the Fire Safety & Property Maintenance codes of New York State and the Town of North Castle):

- ☐ Exit signs & emergency lights as required lights must be operational.
- ☐ Fire extinguishers as required must have current service tags.
- ☐ Egress doors as required all must be in working order.
- ☐ Corridors must be clean and open without any obstruction to all egress doors.
- ☐ Emergency escape openings shall be maintained in accordance with the code.
- ☐ Boiler rooms must have adequate fresh air, self-closing fire rated doors.
- ☐ Fire Sprinkler Systems must be operational, if applicable.
- ☐ All required fire protection systems, equipment, and/or facilities.

***Note** this is not an all-inclusive list of requirements; such specific requirements are found in related codes.

RESUMEN de Requisitos (por parte de los codigos del mantenimiento de la seguridad y de la característica de fuego del estado de Nueva York y del Pueblo de North Castle:

- ☐ Letreros de exito y luces de emergencia deben estar en orden operacional.
- ☐ Los extinguidores de incendio deben tener etiquetas de servicio con fechas corriente.
- ☐ Puertas de salida deben estar en orden de funcionamiento.
- ☐ Corredores deben estar limpios y mantenidos sin obstruccion a todas las puertas de salida.
- ☐ Todas las salidas de escape de emergencia deben estar funcionando en acuerdo con elCodigo.
- ☐ El cuarto que mantiene la caldera (boiler) deben tener puertas clasificades con proteccion de incendio y ventilacion y cerradura automatic.
- ☐ Sistemas de regadera de incendio (si applicable) deben estar en orden operacional.
- ☐ Todos los requistos de sistemas de proteccion de incendios, equip, y facilidades/instalaciones requeridas.

***Por favor** observe esta lista no es la lista inclusiva de requistos; cual tale requistos especificos se encuentran en los codigos relacionados con la Seguridad de Incendios y leyes/Codigos del Pueblo de North Castle y el Estado de Nueva York.